



ICC
EVALUATION
SERVICE

In Cooperation with



Most Widely Accepted and Trusted

ESR-1233

Reissued 02/2019

Revised 03/2019

This report is subject to renewal 02/2020.

ICC-ES Evaluation Report

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION

SECTION: 07 25 00—WATER-RESISTIVE BARRIERS/WEATHER BARRIERS

SECTION: 07 27 00—AIR BARRIERS

REPORT HOLDER:

STO CORP.

EVALUATION SUBJECT:

**STOGUARD® WITH GOLD COAT®, STOGUARD® WITH EMERALDCOAT®,
STOGUARD® VAPORSEAL R™ AND STOGUARD® AIRSEAL™ AIR BARRIER AND
WATER-RESISTIVE BARRIERS, STOENERGY GUARD
(STOGUARD WITH CONTINUOUS INSULATION) AND STOPANEL BACKUP**



"2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence"



ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



Copyright © 2019 ICC Evaluation Service, LLC. All rights reserved.

ICC-ES Evaluation Report

ESR-1233

Reissued February 2018

Revised March 2019

This report is subject to renewal February 2020.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION

Section: 07 25 00—Water-resistive Barriers/Weather Barriers

Section: 07 27 00—Air Barriers

REPORT HOLDER:

STO CORP.

ADDITIONAL LISTEES:

PROSOCO, INC.

KAPTURE PREFAB

EVALUATION SUBJECT:

STOGUARD® WITH GOLD COAT®, STOGUARD® WITH EMERALDCOAT®, STOGUARD® VAPORSEAL-R™ AND STOGUARD® AIRSEAL™ AIR BARRIER AND WATER-RESISTIVE BARRIERS, STOENERGY GUARD (STOGUARD WITH CONTINUOUS INSULATION) AND STOPANEL BACKUP

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2015, 2012, and 2009 *International Building Code*® (IBC)
- 2015, 2012, and 2009 *International Residential Code*® (IRC)
- 2015, 2012, and 2009 *International Energy Conservation Code*® (IECC)
- 2013 *Abu Dhabi International Building Code* (ADIBC)†

†The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

Properties evaluated:

- Surface-burning characteristics
- Fire-resistance-rated construction
- Water-resistive barrier
- Air leakage
- Types I, II, III and IV Construction

1.2 Evaluation to the following green code(s) and/or standards:

- 2016 California Green Building Standards Code (CALGreen), Title 24, Part 11

- 2015 and 2012 *International Green Construction Code*® (IgCC)

- 2014 and 2011 ANSI/ASHRAE/USGBC/IES Standard 189.1—Standard for the Design of High-Performance Green Buildings, Except Low-Rise Residential Buildings

- 2015, 2012 and 2008 ICC 700 *National Green Building Standard*™ (ICC 700-2015, ICC 700-2012 and ICC 700-2008)

Attributes verified:

See Section 3.1

2.0 USES

2.1 StoGuard® Air Barrier and Water-resistive Barriers:

StoGuard® with Gold Coat®, StoGuard® with EmeraldCoat®, StoGuard® VaporSeal R™ and StoGuard® AirSeal™ are used as alternatives to the water-resistive barrier specified in Section 1404.2 of the IBC and Section R703.2 of the IRC when installed over wood and gypsum-based sheathing. They are also used as air barrier materials in accordance with the IRC Section N1102.4, 2015 IECC Sections C402.5 and R402.4, and 2012 IECC Sections C402.4 and R402.4 (2009 and 2006 IECC Sections 402.4 and 502.4).

StoGuard® with Gold Coat®, StoGuard® with EmeraldCoat®, StoGuard® VaporSeal R™ and StoGuard® AirSeal™ water-resistive barriers may be used in all types of construction, except that under the 2012 IBC for Types I through IV construction, use is limited to exterior walls of buildings having a maximum height of 40 feet (12.2 m) above grade plane, in accordance with 2012 IBC Section 1403.5, unless the exterior wall assemblies are installed as described in Section 4.7 of this report. Under the 2015 IBC for Types I, II, III, or IV construction, use is limited to exterior walls of buildings having a maximum height of 40 feet (12.2 m) above grade plane, in accordance with 2015 IBC Section 1403.5, unless the exterior wall assemblies are installed as described in Section 4.7 of this report. For exterior walls of buildings of Types I, II, III, or IV construction that are greater than 40 feet (12.2 m) above grade plane, StoGuard® with Gold Coat®, StoGuard® with EmeraldCoat®, StoGuard® VaporSeal R™ and StoGuard® AirSeal™ water-resistive barriers may be used, in accordance with 2015 IBC Section 1403.5, Exception 1. StoGuard® with Gold Coat®, StoGuard® with EmeraldCoat®, StoGuard® VaporSeal R™ and StoGuard® AirSeal™ may also be used in construction permitted under the IRC.

StoGuard® with Gold Coat® (with Sto Gold Fill and Sto Detail Mesh), when installed at a maximum thickness of 10 mils [0.01 inch (0.25 mm)], may be used in exterior walls of fire-resistance-rated construction assemblies recognized in the 2015 and 2012 IBC Table 721.1(2) (2009 IBC Table 720.1(2)), without changing the assigned hourly rating of the assembly. StoGuard® with Gold Coat® complying with ASTM E2570 is used over sheathing where EIFS cladding is to be used. StoGuard® with Gold Coat® may be used behind other wall covering materials.

A single layer of StoGuard® with Gold Coat® or StoGuard® with EmeraldCoat® is vapor-permeable and is equivalent to a 60-minute, Grade D barrier and may be used when installed in accordance with the Exception to IBC Section 2510.6 and 2015 IRC Section R703.7.3 and 2012 and 2009 IRC Section R703.6.3.

StoGuard® with EmeraldCoat® is used over sheathing where EIFS cladding will not be used. StoGuard® VaporSeal R™ is a Class I vapor retarder which may be used where required by 2015, 2012 and 2009 IBC Section 1405.3, 2015 and 2012 IRC Section R702.7 and 2009 IRC Section R601.3, or 2015 IECC R402.1.1.

StoPanel Backup is StoGuard® with Gold Coat® factory-applied to prefabricated panels by Kapture Prefab using the Sto components recognized in this report.

2.2 StoEnergy Guard (StoGuard® Water-resistive Coatings with Continuous Insulation):

StoEnergy Guard may be used in all types of construction. When used in Types I, II, III and IV construction, the wall assemblies must comply with Section 4.8 of this report.

2.3 StoPanel Backup (StoGuard® Applied to Prefabricated Panels):

StoPanel Backup may be used in all types of construction. When used in Types I, II, III and IV construction, the wall assemblies must comply with Section 4.8 of this report.

3.0 DESCRIPTION

3.1 General:

3.1.1 StoGuard Water-resistive Coatings: The StoGuard® water-resistive coating system consists of a sheathing joint treatment, a rough opening treatment and a water-resistive barrier coating. The joint treatment consists of: 266 Sto Gold Fill® and 919 Sto Detail Mesh (interchangeable with 276 StoGuard Mesh or 278 StoGuard Mesh, which vary in width only), or 270 StoGuard RapidSeal™ with 276 StoGuard Mesh, or 207/208 StoGuard Fabric, or 295 StoGuard RapidFill™. The water-resistive barrier coating is either Sto Gold Coat®, Sto EmeraldCoat®, Sto VaporSeal R™ or StoGuard® AirSeal™. StoGuard® coating systems have a flame-spread index of 25 or less and a smoke-developed index of 450 or less when tested in accordance with ASTM E84.

The attributes of the StoGuard® water-resistive coating system have been verified as conforming to the requirements of (i) 2016 CALGreen Section 5.407.1 for water-resistive barriers; (ii) ICC 700-2015 Sections 602.1.8, 11.602.1.8 and 12.6.602.1.8; ICC 700-2012 Sections 602.1.8, 11.602.1.8 and 12.5.602.1.8; and (iii) ICC 700-2008 Section 602.9 for water-resistive barriers.

The attributes of the StoGuard with Gold Coat, StoGuard with EmeraldCoat, StoGuard VaporSeal R™ and StoGuard® AirSeal™ have been verified as conforming to the requirements of (i) 2016 CALGreen Section A4.407.5

for air barriers; (ii) 2015 and 2012 IgCC Section 605.1.2.1 for air barriers; and (iii) 2014 ASHRAE 189.1 Section 7.3.1.1 and 2011 ASHRAE 189.1 Section 7.4.2.9 for air barriers.

Note that decisions on compliance for those areas rest with the user of this report. The user is advised of the project-specific provisions that may be contingent upon meeting specific conditions, and the verification of those conditions is outside the scope of this report. These codes or standards often provide supplemental information as guidance.

3.1.1.1 266 Sto Gold Fill®: 266 Sto Gold Fill® is a ready-mixed, flexible joint compound packaged in 5-gallon (19 L) pails, having a one-year shelf life when stored at temperatures between 38°F and 90°F (3.3°C and 32.2°C). The product is also sold under the name PROSOCO R-Guard Fill.

3.1.1.2 265 Sto Gold Coat®: 265 Sto Gold Coat® is a ready-mixed, flexible, polymer-based liquid coating packaged in 5-gallon (19 L) pails, having a one-year shelf life when stored at temperatures between 38°F and 90°F (3.3°C and 32.2°C). The product is also sold under the name PROSOCO R-Guard Spray Wrap.

3.1.1.3 919 Sto Detail Mesh: 919 Sto Detail Mesh is a 4.2 oz/yd² (142 g/m²), polymer-coated, glass-fiber reinforcing mesh packaged in 9-inch-wide-by-150-foot-long (229 mm by 46 m) rolls. The product is also sold under the name PROSOCO R-Guard Tape 9.5 (interchangeable with PROSOCO R-Guard 4.25).

3.1.1.4 207/208 StoGuard Fabric: The fabric is a nonwoven cloth reinforcement packaged in 4-inch (102 mm) and 6-inch (152 mm) rolls. The product is also sold under the name PROSOCO R-Guard Joint Fabric.

3.1.1.5 264 Sto EmeraldCoat®: Sto EmeraldCoat® is a ready-mixed, flexible, polymer-based liquid coating packaged in 5-gallon (19 L) pails and having a one-year shelf life when stored at temperatures between 38°F and 90°F (3.3°C and 32.2°C). The product is also sold under the name PROSOCO R-Guard MVP.

3.1.1.6 263 Sto VaporSeal R™: Sto VaporSeal R™ is a ready-mixed polymer-based liquid coating packaged in 5-gallon (19 L) pails, having a one-year shelf life when stored at temperatures between 38°F and 90°F (3.3°C and 32.2°C).

3.1.1.7 Sto AirSeal™: Sto AirSeal™ is a ready-mixed polymer-based liquid coating packaged in 5-gallon (19 L) pails, having a one-year shelf life when stored at temperatures between 38°F and 90°F (3.3°C and 32.2°C).

3.1.1.8 270 StoGuard RapidSeal™: StoGuard RapidSeal is a one-component flexible joint sealant and transition detailing material packaged in 29-ounce (0.86 L) cartridges having a one-year shelf life when stored at temperatures between 33°F and 80°F (0.6°C and 27°C).

3.1.1.9 295 StoGuard RapidFill™: StoGuard RapidFill™ is a one component joint and seam filler used to seal sheathing joints, seams, cracks and transitions for above grade wall construction, packed in 29 oz. (0.86 L) cartridges or 20 oz. (0.6 kg) sausages having a one year life when stored at temperatures between 33°F and 80°F (0.6°C and 27°C). The product is also sold under the name PROSOCO R-Guard Joint and Seam Filler.

3.1.2 StoEnergy Guard (StoGuard Water-resistive Coating with Continuous Insulation): When the StoGuard water-resistive coating system described in Section 3.1.1 is installed in conjunction with Dow

Styrofoam Type IV foam plastic insulation complying with ESR-2142, the system is recognized as StoEnergy Guard.

3.2 Air Permeance:

When installed in accordance with Section 4.1 and tested in accordance with ASTM E2178, the StoGuard with Gold Coat, StoGuard with EmeraldCoat, StoGuard VaporSeal R™ and StoGuard AirSeal™ have an air leakage rate of less than 0.02 L/(sm²) @ 75 Pa [0.004 cfm/ft² @ 0.3 inch w.g. (1.57 psf)].

3.3 Water Vapor Transmission:

The desiccant method water vapor transmission (WVT) values of the StoGuard with Gold Coat, StoGuard with EmeraldCoat and StoGuard VaporSeal R™ vapor permeable materials, as determined in accordance with ASTM E96 are as follows:

Sto EmeraldCoat®:

- Single layer 8.5 Perms = 58.7 g/m² per 24 hours
- Double layer 3.5 Perms = 24.5 g/m² per 24 hours

Sto Gold Coat®:

- Single layer 7.7 Perms = 53.1 grams/m² per 24 hours
- Double layer 3.1 Perms = 21.8 grams/m² per 24 hours

Sto VaporSeal™:

- Double layer 0.092 Perms = 0.59 g/m² per 24 hours

Sto Gold Fill® with Sto Detail Mesh: 7.10 perm = 119 grams/m² per 24 hours

The water vapor transmission (WVT) value of the Sto Air Seal material, as determined in accordance with ASTM E96 (Water Method) is as follows:

- Sto AirSeal™: 14.2 perms = 93.4 grams/m² per 24 hours

3.4 Substrates:

The use of StoGuard® water-resistive coating systems is limited to applications over the following substrates:

- Glass mat faced gypsum recognized in a current evaluation report as complying with ASTM C1177.
- Plywood, Exposure 1 exterior grade, complying with U.S. DOC PS-1, except as noted in Section 5.7.
- Oriented Strand Board (OSB), Exposure 1, complying with U. S. DOC PS-2, except as noted in Section 5.7.
- Concrete and masonry complying with the applicable code.

4.0 INSTALLATION

4.1 General:

Installation of StoGuard® water-resistive coating system must comply with this report and the manufacturer's published installation instructions. The manufacturer's published installation instructions must be available at the jobsite at all times during installation.

4.2 Substrate Preparation:

StoGuard® water-resistive barrier coating systems are installed on the exterior side of vertical exterior walls. Surfaces must be free of all bond-inhibiting materials, including dirt, oil and other foreign matter. StoGuard® water-resistive barrier coating systems must be applied only when the surface and ambient temperatures are 40°F (4°C) and rising during the application and drying period. Working time will decrease as surface and ambient temperatures increase.

StoGuard® water-resistive barrier coating systems must not be installed on damp surfaces, below-grade surfaces,

or on surfaces subject to water immersion. Damaged sheathing must be removed and replaced. Sheathing must be installed as required by the applicable code. StoGuard® water-resistive coating system must be covered with an exterior wall finish complying with the requirements of the applicable code or a current evaluation report.

Sto Gold Fill® must be troweled over all sheathing joints, rough openings, and inside and outside building corners. Sto Detail Mesh shall be immediately embedded in the Sto Gold Fill® and troweled smooth. Sheathing joints require a minimum 4-inch (101 mm) width of mesh. Rough openings and corners require a minimum 9-inch (228 mm) width of mesh. Fastener heads and surface defects must be spot-coated with Sto Gold Fill®. The system must not be applied over irregular surfaces. The substrate to be coated must be continuous, without joints, holes, etc., exceeding 1/32 inch (0.8 mm) in size. Surface defects larger than 1/32 inch (0.8 mm) must be treated with Sto Gold Fill® prior to application of Sto Gold Coat®. The application thickness of Sto Gold Fill™ must not exceed 1/16 inch (1.6 mm).

StoGuard RapidSeal is applied with a caulking gun and spread with a plastic drywall knife to a minimum thickness of 12 mils [0.012 inch (0.305 mm)] over 2-inch-wide (51 mm) StoGuard Mesh centered over sheathing joints, except for corners where 4-inch-wide (102 mm) mesh is used. At rough openings the material is spread over the entire rough opening and 4-6 inches (102-152 mm) onto the sheathing surface. Rough openings do not require the mesh. Use of the StoGuard RapidSeal is limited to use over plywood and glass mat faced gypsum sheathing as described in Section 3.3 of this report. Use of the StoGuard RapidSeal with Sto EmeraldCoat or Sto VaporSeal is outside the scope of this report.

StoGuard RapidFill is applied with a caulking gun and spread with a plastic drywall knife over sheathing joints, and inside and outside corners, to a minimum thickness of 20 mils (0.5 mm), 1 inch beyond the sheathing joint on each side. After drying it is top coated with any of the StoGuard water-resistive coatings.

StoGuard Fabric may be used in lieu of Sto Gold Fill as a joint treatment. Sto Gold Coat, Sto EmeraldCoat, or Sto VaporSeal R™ or StoGuard AirSeal™ is applied by spray, brush or roller to the joint area, and StoGuard Fabric is immediately embedded in the wet material by placing the fabric and then brushing or rolling over it. After drying, a second coat of Sto Gold Coat, Sto EmeraldCoat, or Sto VaporSeal R™ or StoGuard AirSeal™ is applied over the joint as described in Section 4.3, 4.4, or 4.5, respectively.

4.3 Sto Gold Coat® Application:

4.3.1 Sto Gold Coat® Application over Exterior Gypsum Sheathing, Glass Mat Faced Gypsum or Exterior Plywood: The substrate must be prepared as described in Section 4.2. Sto Gold Coat® must be applied with a nap roller in a single, uniform coat to a wet thickness of 10 mils [0.01 inch (0.25 mm)]. For application over glass mat faced gypsum sheathing, a 3/4-inch (19.1 mm) nap roller must be used. For application over plywood and gypsum sheathing, a 1/2-inch (12.7 mm) nap roller must be used. The coating must not be applied in rainy conditions.

4.3.2 Sto Gold Coat® Application over Oriented Strand Board (OSB): A two-coat application of Sto Gold Coat® is required over OSB. The first coat of Sto Gold Coat® must be applied over the substrate prior to treatment of sheathing joints, rough openings, and corners. The second coat of Sto Gold Coat® must be applied to the prepared substrate, as described in Section 4.2, with a 3/4-inch (19.1 mm) nap roller. The substrate receiving the second coat of Sto Gold Coat® must be continuous, without joints,

holes, etc., exceeding $\frac{1}{32}$ inch (0.8 mm) in size. The second coat of Sto Gold Coat® must be applied over the treated surface in a single, uniform coating to a wet thickness of 10 mils [0.01 inch (0.25 mm)]. The coating must not be applied in rainy conditions.

4.3.3 Sto Gold Coat Application over Concrete and Concrete Masonry: The substrate must be prepared as indicated in Section 4.2 of this report. For concrete substrates, a single uniform coat is applied by spray or roller to a wet thickness of 10 mils [0.01 inch (0.25 mm)]. For concrete masonry substrates, two single uniform coats are applied by spray or roller to a wet thickness of 15 mils [0.015 inch (0.38 mm)] each, or there is one uniform spray application to a wet thickness of 30 mils [0.03 inch (0.76 mm)].

4.3.4 Curing and Drying: Sto Gold Coat® must be dry to the touch and may be over-coated within two to four hours after application, under normal conditions. Drying time varies depending on temperature/humidity and surface conditions. A minimum of 24 hours is required before any adhesive attachment of exterior finish to the final StoGuard® system surface is made, if required. Surfaces must be protected from rain and freezing until completely dry.

4.4 Sto EmeraldCoat® Application:

4.4.1 Sto EmeraldCoat® Application over Sheathing: The substrate must be prepared as described in Section 4.2. Sto EmeraldCoat® is applied with a nap roller or appropriate spray equipment in a single uniform coat to a wet thickness of 10 mils [0.01 inch (0.25 mm)]. For application over glass mat faced gypsum sheathing and orientated strand board (OSB) a $\frac{3}{4}$ -inch (19.1 mm) nap roller is used. OSB sheathing may require touch-up with a second application of Sto EmeraldCoat® where wood strands are raised. Surfaces must be inspected and touched up as needed before installation of wall covering materials. For application over plywood and gypsum sheathing, a $\frac{1}{2}$ -inch (12.7 mm) nap roller is used. The coating must not be applied in rainy conditions.

4.4.2 Sto EmeraldCoat Application over Concrete and Concrete Masonry: The substrate must be prepared as indicated in Section 4.2 of this report. For concrete substrates, a single uniform coat is applied by spray or roller to a wet thickness of 10 mils [0.01 inch (0.25 mm)]. For concrete masonry substrates, two single uniform coats are applied by spray or roller to a wet thickness of 15 mils [0.015-inch (0.38 mm)] each, or there is one uniform spray application to a wet thickness of 30 mils [0.03 inch (0.76 mm)].

4.4.3 Curing and Drying: Sto EmeraldCoat® must be dry to the touch and may be over-coated within two to four hours after application. Drying time varies depending on temperature/humidity and surface conditions. Surfaces must be protected from rain and freezing until completely dry.

4.5 Sto VaporSeal R™ and StoGuard AirSeal™ Application:

4.5.1 Sto VaporSeal R™ and StoGuard AirSeal™ Application over Approved Substrates: The substrate must be prepared as described in Section 4.2. Sto VaporSeal R™ and StoGuard AirSeal™ is applied with appropriate spray equipment in a single uniform coat to a minimum wet thickness of 46 mils [0.046 inch (1.16 mm)] for Sto VaporSeal R™ and a minimum wet thickness of 40 mils [0.040 inch (1.00 mm)] for StoGuard® AirSeal™. They may also be applied in multiple coats with a $\frac{3}{4}$ -inch

(19 mm) nap roller to achieve the same thickness. The coating must not be applied in rainy conditions.

4.5.2 Curing and Drying: Sto VaporSeal R™ and StoGuard AirSeal™ must be dry to the touch and may be overcoated within two to four hours after application. Drying time varies depending on temperature/humidity and surface conditions. Surfaces must be protected from rain and freezing until the materials are completely dry.

4.6 StoEnergy Guard:

The StoGuard water-resistive coating must be installed over the substrates as described in Section 4.0 of this report. The Dow Styrofoam foam plastic insulation board must be installed in accordance with [ESR-2142](#). The foam plastic board may be installed directly over the framing or directly over the exterior wall sheathing or substrate. Installation of the exterior wall sheathing and exterior cladding must be done to the satisfaction of the code official

4.7 StoPanel Backup:

The StoGuard water-resistive coating must be installed over the substrates as described in Section 4.0 of this report.

4.8 Use on Exterior Walls in Types I, II, III and IV Construction:

When used in exterior walls of Types I, II, III and IV construction and when installed in accordance with this report, the assemblies shown in Tables 1 and 2 of this report comply with NFPA 285 and the provisions shown in IBC Section 2603.5, when using Dow Styrofoam foam plastic insulation as described in Tables 1 and 2 of this report.

5.0 CONDITIONS OF USE

The StoGuard® water-resistive coating systems, StoEnergy Guard and StoPanel Backup described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Installation must comply with this report, the manufacturer's published instructions and the applicable code. In the event of a conflict between the manufacturer's published installation instructions and this report, this report governs.
- 5.2 For EIFS applications, special inspections are required at the jobsite in accordance with 2015 and 2012 IBC Section 1705.15.1 (2009 IBC Section 1704.14.1). For other applications, special inspections are not required at the jobsite if installation is done by an installer or contractor trained by the manufacturer, and a certificate of installation is presented to the code official at the completion of each project; otherwise, special inspections are required at the jobsite in accordance with 2015 and 2012 IBC Section 1705.1.1 (2009 IBC Section 1704.15). Duties of the inspector include verifying field preparation of materials, expiration dates, installation of components, curing of components, installation of joints and sealants, applied dry-film thickness and interface of coating material with flashings. Special inspections are not required under the 2015, 2012 and 2009 IRC.
- 5.3 The StoGuard® air barrier and water-resistive barrier systems, StoEnergy Guard and StoPanel Backup are limited to installations on walls.
- 5.4 The Sto Guard® water-resistive barrier coating system and StoEnergy Guard must be covered with an

exterior wall finish or covering complying with the applicable code or a current evaluation report.

- 5.5 The Sto Guard® water-resistive barrier coating system and StoEnergy Guard must not be used for repairing moving cracks, joints or cracks wider than $\frac{1}{8}$ inch (3.2 mm).
- 5.6 For exterior wall assemblies consisting of the StoEnergy Guard, the Dow Styrofoam foam plastic insulation board must also be installed in accordance with the requirements set forth in [ESR-2142](#).
- 5.7 The use of Sto AirSeal™ with exterior stucco systems is limited to application over ASTM C1177 sheathing or concrete or masonry wall substrates under the 2015 IBC.

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with the ICC-ES Acceptance Criteria for Water-resistive Coatings Used as Water-resistive Barriers over Exterior Sheathing (AC212), dated February 2015.
- 6.2 NFPA 285 test and analysis.

7.0 IDENTIFICATION

- 7.1 Packages of the Sto system products described in this report must be identified by a label bearing the manufacturer's name (Sto Corp.) and address, product name, identification of components, lot or batch number, quantity of material in packaged mix, storage instructions and shelf life, expiration date (when applicable) and the evaluation report number (ESR-1233).

Dow Styrofoam foam plastic insulation must be labeled in accordance with [ESR-2142](#).

StoPanel Backup prefabricated panels are produced by Kapture Prefab and shipped with a certificate of compliance that contains the project identification the panels were produced for, dates of panel fabrication and a statement that all components of the panels comply with the applicable requirements of ESR-1233.

- 7.2 The report holder's contact information is the following:

STO CORP.
3800 CAMP CREEK PARKWAY
BUILDING 1400, SUITE 120
ATLANTA, GEORGIA 30331
(404) 346-3666
www.stocorp.com

- 7.3 The Additional Listees' contact information is the following:

PROSOCO, INC.
3741 GREENWAY CIRCLE
LAWRENCE, KANSAS 66046
(785) 830-7355

KAPTURE PREFAB
421 WEST ALAMEDA DRIVE
TEMPE, ARIZONA 85282

TABLE 1—STOENERGY GUARD WALL ASSEMBLIES FOR TYPES I, II, III AND IV CONSTRUCTION (XPS INBOARD OF SHEATHING)¹

WALL COMPONENT	MATERIALS
Base Wall System—Use either 1, 2 or 3	1-Concrete wall 2-Concrete masonry wall 3-1 layer of 5/8-inch-thick Type X gypsum wallboard (on interior), installed over steel studs (minimum 33/8-inch deep, minimum No. 18 gage, maximum 16-inch o.c.)
Floorline Firestopping	4 pcf, mineral wool insulation in each stud cavity and at each floorline- attached with Z-clips or equivalent
Stud Cavity Insulation—Use either 1, 2 or 3	1-None 2-Fibergalss batt insulation (faced or unfaced) 3-Any non-combustible material
Continuous Insulation—Use either 1 or 2	1-None 2-ASTM C578 Type IV, Dow Styrofoam insulation board recognized in ESR-2142: 1/2-inch minimum to 3-inch maximum; insulation board joints may be covered with 4-inch (maximum) wide asphalt or butyl-based flashing tape
Exterior Sheathing over Continuous Insulation No. 2 and Base Wall System No. 3—Use either 1 or 2. Exterior Sheathing over Base Wall System No. 3 without Continuous Insulation No. 2—Use either 1 or 2	1-5/8-inch thick Type X glass mat gypsum sheathing complying with ASTM C1177 2-1/2-inch thick glass mat gypsum sheathing <i>Note: Seal exterior sheathing joints with materials and procedures as identified in Section 3.0 of this report.</i>
Air and water-resistive barrier coating applied to Base Wall System 1 or 2 without Continuous Insulation No. 2 and without exterior sheathing—Use either 1, 2, 3 or 4. Air and water-resistive barrier coating applied to exterior sheathing of Base Wall System 3—Use either 1, 2, 3 or 4.	1-Sto Gold Coat 2-Sto EmeraldCoat 3-Sto VaporSeal R 4-Sto AirSeal ³
Secondary water-resistive barrier membrane—Use either 1 or 2	1-None 2-No 15 asphalt-saturated felt complying with ASTM D226 for Type I 3-Grade D paper water-resistive barrier specified in 2012 and 2009 IBC and 2012 and 2009 IRC
Drainage Mat—Use either 1 or 2	1-None 2-Sto DrainScreen ²
Exterior Veneer—Use either 1, 2, 3, 4, 5, 6, 7 or 8	1-Stucco-Minimum 3/4-inch thick exterior cement plaster and lath complying with code. As an option, adhered masonry veneer, such as: thin brick, manufactured stone, ceramic or porcelain tile may be installed over the stucco. 2-Brick-Use standard 4-inch thick, clay brick. Use standard brick veneer anchors installed vertically on each stud at a maximum of 24-inch o.c. creating a 2-inch maximum air gap between the continuous insulation and the brick. 3-Concrete- Minimum 2-inch thick, with a maximum 2-inch air gap between continuous insulation and concrete. 4-Concrete masonry units- Minimum 4-inch thick with a 2-inch maximum air gap between the continuous insulation and the concrete masonry units. 5-Limestone- minimum 2-inch thick using any standard non-open joint installation such as ship lap. 6-Natural stone veneer- minimum 2-inch thick installed using any standard non-open joint installation such as ship lap. 7-Pre-cast artificial stone complying with ICC-ES AC51-minimum 1 1/2-inch thick installed using any standard non-open joint installation technique such as ship lap. 8-Terracotta cladding- minimum 1 1/4-inch thick installed using any standard non-open joint installation technique such as ship-lap.
Special Conditions	For Exterior Veneers 2 through 7 use header treatment as shown in Figures 5, 6 and 7 of ESR-2142 for all window and door openings.

¹Wall components must be installed in accordance with the code or applicable ICC-ES evaluation report to the satisfaction of the code official.

²This material was evaluated only for compliance with NFPA 285, when used as part of the wall assemblies outlined in Table 1.

**TABLE 2—STOENERGY GUARD WALL ASSEMBLIES FOR TYPES I, II, III AND IV CONSTRUCTION
(XPS OUTBOARD OF SHEATHING)¹**

WALL COMPONENT	MATERIALS
Base Wall System—Use either 1, 2 or 3	1-Concrete wall 2-Concrete masonry wall 3-1 layer of 5/8-inch thick Type X gypsum wallboard (on interior), installed over steel studs (minimum 33/8-inch deep, minimum No. 18 gage, maximum 16-inch o.c.)
Floorline Firestopping	4 pcf, mineral wool insulation in each stud cavity and at each floorline- attached with Z-clips or equivalent
Stud Cavity Insulation—Use either 1, 2 or 3	1-None 2-Fibergalss batt insulation (faced or unfaced) 3-Any non-combustible material
Exterior Sheathing applied to Base Wall System No. 3—Use either 1 or 2. Exterior sheathing is not required for Base Wall Systems 1 or 2.	1-5/8-inch thick Type X glass mat gypsum sheathing complying with ASTM C1177 2-1/2-inch thick glass mat gypsum sheathing <i>Note: Seal exterior sheathing joints with materials and procedures as identified in Section 3.0 of this report.</i>
Air and water-resistive barrier coating applied to Base Wall System 1, 2 or 3 (concrete, concrete masonry or exterior sheathing)—Use either 1, 2, 3 or 4	1-Sto Gold Coat 2-Sto Emerald Coat 3-Sto VaporSeal R 4-Sto AirSeal ³
Continuous Insulation adhesive—Use either 1 or 2	1-None 2-Sto TurboStick Adhesive ²
Continuous Insulation—Use either 1 or 2	1-None 2-ASTM C578 Type IV, Dow Styrofoam insulation board recognized in ESR-2142: 1/2-inch minimum to 3-inch maximum; insulation board joints may be covered with 4-inch (maximum) wide asphalt or butyl-based flashing tape
Secondary water-resistive barrier membrane—Use either 1, 2 or 3	1-None 2-No. 15 asphalt-saturated felt complying with ASTM D226 for Type I 3-Grade D paper water-resistive barrier specified in the 2012 and 2009 IBC and 2012 and 2009 IRC
Drainage Mat—Use either 1 or 2	1-None 2-Sto DrainScreen ² installed either over the air barrier and water-resistive barrier coatings or over the continuous insulation
Exterior Veneer—Use either 1, 2, 3, 4, 5, 6, 7 or 8	1-Stucco-Minimum 3/4-inch thick exterior cement plaster and lath complying with code. As an option, adhered masonry veneer, such as: thin brick, manufactured stone, ceramic or porcelain tile may be installed over the stucco. 2-Brick-Use standard 4-inch thick, clay brick. Use standard brick veneer anchors installed vertically on each stud at a maximum of 24-inch o.c. creating a 2-inch maximum air gap between the exterior insulation and the brick. 3-Concrete- Minimum 2-inch thick, with a maximum 2-inch air gap between exterior insulation and concrete. 4-Concrete masonry units- Minimum 4-inch thick with a 2-inch maximum air gap between the exterior insulation and the concrete masonry units. 5-Limestone- minimum 2-inch thick using any standard non-open joint installation such as ship lap. 6-Natural stone veneer- minimum 2-inch thick installed using any standard non-open joint installation such as ship lap. 7-Pre-cast artificial stone complying with ICC-ES AC51-minimum 1 1/2-inch thick installed using any standard non-open joint installation technique such as ship lap. 8-Terracotta cladding- minimum 1 1/4-inch thick installed using any standard non-open joint installation technique such as ship-lap.
Special Conditions	For Exterior Veneers 2 through 7 use header treatment as shown in Figures 5, 6 and 7 of ESR-2142 for all window and door openings.

¹Wall components must be installed in accordance with the code and applicable ICC-ES evaluation report.

²This material was evaluated only for compliance with NFPA 285, when used as part of the wall assemblies outlined in Table 2.

ICC-ES Evaluation Report

ESR-1233 FBC Supplement

Reissued February 2019

Revised March 2019

This report is subject to renewal February 2020.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION

Section: 07 25 00—Water-resistive Barriers/Weather Barriers

Section: 07 27 00—Air Barriers

REPORT HOLDER:

STO CORPORATION

EVALUATION SUBJECT:

STOGUARD® WITH GOLD COAT®, STOGUARD® WITH EMERALDCOAT®, STOGUARD® VAPORSEAL R™ AND STOGUARD® AIRSEAL™ AIR BARRIER AND WATER-RESISTIVE BARRIERS, STOENERGY GUARD (STOGUARD WITH CONTINUOUS INSULATION) AND STOPANEL BACKUP

1.0 REPORT PURPOSE AND SCOPE

Purpose:

The purpose of this evaluation report supplement is to indicate that StoGuard® with Gold Coat®, StoGuard® with EmeraldCoat®, StoGuard® VaporSeal R™, StoGuard® AirSeal™ and StoPanel Backup, recognized in ICC-ES master evaluation report ESR-1233, has also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2017 Florida Building Code—Building
- 2017 Florida Building Code—Residential

2.0 CONCLUSIONS

The StoGuard® with Gold Coat®, StoGuard® with EmeraldCoat®, StoGuard® VaporSeal R™, StoGuard® AirSeal™ and StoPanel Backup, described in Sections 2.0 through 7.0 of the master evaluation report ESR-1233, comply with the 2017 Florida Building Code—Building and 2017 Florida Building Code—Residential, provided the design and installation are in accordance with the 2015 International Building Code® (IBC) provisions noted in the master report.

Use of the StoGuard® with Gold Coat®, StoGuard® with EmeraldCoat®, StoGuard® VaporSeal R™, StoGuard® AirSeal™ and StoPanel Backup for compliance with the High-Velocity Hurricane Zone provisions of the 2017 Florida Building Code—Building and 2017 Florida Building Code—Residential has not been evaluated and is outside the scope of this supplemental report.

For products falling under Florida Rule 9N-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official, when the report holder does not possess an approval by the Commission).

This supplement expires concurrently with the master report, reissued February 2018 and revised March 2019.